

ENBRIDGE GAS DISTRIBUTION INC. RESPONSE TO
FEDERATION OF RENTAL-HOUSING PROVIDERS OF ONTARIO
INTERROGATORY #1

INTERROGATORY

A. RELATED ISSUES

1. Are the proposed facilities needed? Considerations may include but are not limited to demand, reliability, security of supply, flexibility, constraints, operational risk, cost savings and diversity as well as the Board's statutory objectives.

REF: EB-2012-0451 EX. A, Tab 3 Schedule 3

Preamble: EGD has described some of the limitations to its current system. The following are general questions in this area at the outset.

1. For the record, please provide the specific size and maximum allowable operating pressure (MAOP) for:
 - a. the Markham South Lines
 - b. The TCPL lines that travel between Parkway and Markham Gate including the lines that feed from the north to Maple.

RESPONSE

1. (a) Size – NPS 16. Maximum Operating Pressure – 3447 kPa (500 psig).
(b) This is not part of the Enbridge system, so we cannot comment on the size or Maximum Operating Pressure of this line.

Witness: N. Thalassinos