

ENBRIDGE GAS DISTRIBUTION INC. RESPONSE TO
FEDERATION OF RENTAL-HOUSING PROVIDERS OF ONTARIO
INTERROGATORY #17

INTERROGATORY

REF: EB-2012-0451 EX. A, Tab 3 Schedule 3, page 20, Figure 5

17. Using an alternative NPS 16 line from the Markham south line as described in 5f. and the proportional change in throughputs from the four largest Gate stations, please update Figure 5 to show the impact of the alternative line on peak day flows (base line vs. base line and the NPS 16 alternative).

RESPONSE

Alternative NPS 16 line from the end of the new 500 psi Markham south line to the new 36" on the Don Valley line does not meet minimum system pressures at Station B. Please see the response to Federation of Rental Housing Providers of Ontario Interrogatory #5 f) at Exhibit I.A1.EGD.FRPO.5.