

ENBRIDGE GAS DISTRIBUTION INC. RESPONSE TO
ENERGY PROBE RESEARCH FOUNDATION INTERROGATORY #73

INTERROGATORY

Issue D1 Do the facilities address the OEB Environmental Guidelines for Hydrocarbon Pipelines as applicable?

Ref: EB-2012-0451 Exhibit B, Tab 2, Schedule 1, Environmental Report, 5.3 Pre-Consultation, Page 113

Page 113 - Please explain how it was decided that Segment C would not be pursued as part of the GTA project.

RESPONSE

During the stakeholder consultation process, discussions took place on alternatives for the routing of Segment C. The Toronto and Region Conservation Authority had concerns with routings through the sensitive area of the Rosedale valley ravine system. The other alternative route was along the road allowance on Rosedale Valley road. The City of Toronto was concerned with the timing of construction due to the Pan Am Games, and had asked that all construction activity in the vicinity of the games' sites be deferred either to the year prior or after the games. Enbridge reviewed the forecast loads and modeling and determined that this portion of the project could be deferred if the other aspects were in service in 2015.

Witness: C. Fernandes