

ENBRIDGE GAS DISTRIBUTION INC. RESPONSE TO
FEDERATION OF RENTAL-HOUSING PROVIDERS OF ONTARIO
INTERROGATORY #37

INTERROGATORY

REF: EB-2012-0451 EX. E, Tab 1 Schedule 2, page 2, paragraphs 7-8
Conditions Precedent

Please provide the resulting full design capacity if EGD proceeds with the NPS 36 line.

RESPONSE

The design capacity of the NPS 36 would be 1600 TJ/d, with 800 TJ/d reserved for distribution system purposes as per Exhibit E, Tab 1, Schedule 2, paragraph 8.