

ENBRIDGE GAS DISTRIBUTION INC. RESPONSE TO
GEC INTERROGATORY #47

INTERROGATORY

Issue A.1: Need

Reference: Exhibit A, Tab 3, Schedule 9 ¶4 (also Exhibit E.1.2 ¶2)

QUESTION:

Please provide the anticipated capacity of Segment A as NPS 42, in m³/hour.

RESPONSE

The design capacity of Segment A as 27.4 km of NPS 42 is approximately 2000 TJ/day, which equates to approximately 2600 10³m³/hr assuming a 20 hour day to account for peak hourly demand. (See Exhibit E, Tab 1, Schedule 2, Paragraph 2).

Witness: E. Naczynski