

UNDERTAKING JT2.17

UNDERTAKING

TR 2, page 108

Related to BOMA A1- IR25 Table Part D (capacity deficit), to Provide a similar capacity number for the 41 degree day extreme situation.

RESPONSE

At a 41 Degree Day ("DD"), in 2013, the capacity deficit at Station B is approximately 4 TJ/day, and in 2014, the capacity deficit at Station B is approximately 7 TJ/day.

Witness: E. Naczynski