

OSEA INTERROGATORY #7

INTERROGATORY

Reference: Exhibit B, Tab 1, Schedule 6, Page 134 of 271

Preamble: Commercial – Heat Recovery Ventilation – New Construction/Retrofit. The joint submission states that the HRV measure is not eligible in areas where ERV is required by building code.

Given that the Building Code is provincial, how is this decision rule applied?

RESPONSE

In this case, “area” does not refer to geographical location but rather an area within a building. For example, eligibility is restricted where “Special Requirements for Heating, Ventilation, and Air Conditioning (“HVAC”) Systems in Health Care Facilities.” are required. (see “Uses and Exclusions” sub-heading, Exhibit B, Tab 1, Schedule 6, p. 140).

Witnesses: D. Bullock
L. Kulperger