

ENBRIDGE GAS DISTRIBUTION INC. AND UNION GAS LIMITED

Undertaking of Ms. Mikhaila
To Mr. St. Louis

REF: Tr.2 p.119

To advise if the Design Day Demand is typically higher than the Contract Demand Day then as it is with Kitchener Utilities.

Response:

In Union's 2013 Cost of Service, there were 224 contract rate customers with firm service. Of these customers, there were 45 with a design day demand equal to their contract demand, 151 with a design day demand greater than their contract demand, and 28 with a design day demand less than their contract demand. The design day demand for Kitchener Utilities is determined using the same process that is used to determine the design day demands for heat sensitive contract rate customers and Union's general service demands, such as the City of Guelph and the City of Cambridge.

Kitchener Utilities' contract demand changed on April 1, 2011 from 2,558,000 m³/d to the current contract demand of 2,350,000 m³/d.