

ENBRIDGE GAS INC.
Answer to Interrogatory from
EPCOR Natural Gas Limited Partnership (ENGLP)

Reference: Exhibit B1, Tab 1, Schedule 1, p. 40 and Appendix H

Preamble: Appendix H is filed in response to a commitment by Enbridge (in its 2017 ESM Proceeding (EB-2018-0131) to file evidence about the refined feasibility analysis approach for residential infill customers (p. 40).

Appendix H: (a) is said to apply to the “EGD Rate Zone”; (b) purports to address “key elements of the Company policy under the Community Expansion framework as approved by the Board in E-2016-0004 ...”; and (c) sets out Enbridge’s procedures and policies to comply with EBO 188.

Further, paragraph 10 on page 3 of 8 of Appendix H states that “Where the use of a proposed facility is dominated by a single large volume customer, it is conserved a dedicated facility for CIAC purposes.”

Question:

- (a) Please advise whether this policy applies to the Union Rate Zone as well.
- (b) Please advise whether this policy would apply to customers connecting to transmission (as opposed to distribution) assets.
- (c) Could paragraph 10 noted in the preamble above apply to a “facility” connecting to a transmission (as opposed to a distribution) asset? Please provide a definition of “dominant customer”.

Response

- (a) No. Please see Exhibit I.STAFF.2, part (e).
- (b) The enhancements were made to ensure compliance with the distribution system guidelines laid out in EBO 188. Cost estimation for transmission projects has not been affected by this change.

- c) As explained in (b) above, this Policy only applies to connecting to distribution customers. Dominant Customer is a term used to describe a situation when a pipe is extended to serve multiple customers and where one of the customers' peak demand consumes more than 75% of the capacity of the line.